

SS 207 Junction Sealing for Circular Non Man- Entry Sewer Pipe

Table of Contents

Revision details.....	3
Introduction	3
Copyright.....	3
1. General	4
1.1 Introduction.....	4
2. Scope	4
3. Product	4
3.1 Material	4
3.2 Dimensions.....	5
4. Execution	5
4.1 Flow Management.....	5
4.2 Infiltration	5
4.3 Surface Preparation.....	5
4.4 Delivery and Installation of Junction Fittings.....	5
4.5 Testing	6
4.6 Reporting	6
5. References	7
6. Ownership	7
Ownership	7
Change history.....	7

Revision details

Version No.	Clause	Description of revision
4		Transferred content to new Sydney Water Standard Template
3		Revision and renaming of EPS 207 issued in March 2009
2		Document reviewed and updated
1		New Document

Introduction

This Specification is for the design, supply and construction of Junction Sealing for Circular Non Man- Entry Sewer Pipe for Sydney Water assets.

Sydney Water makes no warranties, express or implied, that compliance with the contents of this Specification shall be sufficient to ensure safe systems or work or operation.

It is the user's sole responsibility to ensure that the copy of the Specification is the current version as in use by Sydney Water.

Sydney Water accepts no liability whatsoever in relation to the use of this Specification by any party, and Sydney Water excludes any liability which arises in any manner by the use of this Specification.

For the purpose of this Specification "Sydney Water" is the nominated person or organisation that has written authority to act on Sydney Water's behalf.

This document is uncontrolled once printed or downloaded.

Copyright

The information in this document is protected by Copyright and no part of this document may be reproduced, altered, stored or transmitted by any person without the prior consent of Sydney Water.

1. General

1.1 Introduction

The intent of this specification is to define the requirements for rehabilitating and sealing circular sewer junctions using fittings installed by non-man entry techniques. Sealing shall be such as to prevent leakage and/or root intrusion. The service life shall be at least 50 years.

2. Scope

This specification defines the requirements for manufacture, installation, workmanship and documentation of junction seals installed at sewer junctions from inside. The specification applies to following type of junctions:

- Main sewer and private sewer both unlined
- Main sewer lined but private sewer unlined
- Main sewer and private sewer both lined

The fitting may be in the shape of a T-seal or a Top Hat.

3. Product

3.1 Material

Materials and systems approved for the purpose of junction sealing by the Principal shall only be used. Materials used shall be suitable for long term durability in a sewer environment (Refer Clause 2.1 of SS 201) Materials used for junction sealing fittings shall be such that under cured condition have good adhesions to host surfaces and seal completely.

Materials shall be compatible with any lining material against which the seal will be in contact. It shall be sufficiently robust not to be damaged by pipe cleaning equipment that may be required to remove any future blockage following the installation of the fitting.

The lining shall have the following minimum physical properties:

- Short term flexural strength: 25 MPa
- Short term tensile strength: 20 MPa
- Short term flexural modulus: 2,200 MPa
- Bond strength to host surface: 1.0 MPa
- Capable of withstanding cleaning jet pressure under installed condition of 14 MPa at 5 Litres per second flow rate

3.2 Dimensions

Finished dimensions of junction fittings shall be as follows:

- Exactly fit internal dimensions of host surfaces.
- In case of a T-shaped fitting the length of the fitting arm in the main line shall be at least four (4) times the diameter of the lateral. The lateral arm shall extend at least 1.5 times the lateral diameter on either side of the junction/cut-out for the full circumference of the main line.
- Minimum extension into laterals shall be 400 mm and at least 150 mm passed the first joint in the lateral unless restricted by the host pipe dimension.
- Permissible thickness of the liner shall be as assessed by the principal.

4. Execution

4.1 Flow Management

The Contractor shall arrange for flow isolation and/or flow by passing to avoid any over-flow from main and private sewers.

If flow isolation is required, then the Contractors shall advise the Customer accordingly and make alternative arrangement for the Customer.

4.2 Infiltration

The Contractor shall be responsible for the control of infiltration using chemical grout or other approved means so that the quality of repair is not affected by infiltration

4.3 Surface Preparation

The Contractor shall prepare pipe junctions for installation of junction-sealing fittings. Junctions shall be cleaned and all roots removed. All surfaces that will be in contact with fittings shall be thoroughly cleaned so that good adhesion can be achieved. High-pressure air, steam or water cleaning, with or without cleaning agents shall be used to clean the host surfaces.

Care shall be taken during cleaning to avoid any damage to existing surfaces. Adequacy of cleaning shall be ensured by CCTV inspections.

Where necessary the Contractor shall trim the existing edges of the junction rim (cut out rim) to ensure that the lateral seal can be installed to fit the junction smoothly.

4.4 Delivery and Installation of Junction Fittings

Immediately prior to installation of a junction fitting the Contractor shall clean and CCTV the junction.

The Contractor shall not proceed with an installation in situations where there is a considerable risk that such an attempted will be unsuccessful. The Contractor shall take due note of prevailing ambient conditions (e.g. temperature, humidity, etc.) and plan installation times accordingly.

Where it is required to install a liner in the main sewer and/or in the private sewer then the work shall be sequenced such that junction seal is installed last.

Delivery and installation of the junction seal shall be carried out in accordance with a work method purpose written for the system. The specification shall cover different cases where the main line and lateral are lined or unlined. The Contractor upon request shall provide a copy of this work method to the Principal.

After curing, exposed surfaces of fittings shall be smooth. Fittings shall be free of any defect that affects the hydraulic or structural performance or the general quality.

Defects that are considered unacceptable include but are not limited to the following:

- Foreign inclusion
- Inadequate pipe preparation
- Leakage through repairs
- Bubbles or voids or blisters
- Inadequate material curing
- Poor finishing at corners and ends
- Inadequate bond
- Shrinkage
- Gap between the host surface and the fitting

4.5 Testing

The Contractor quality control system shall include methods to record details of the installation, impregnation and curing times for each installation.

The tests listed in this clause shall be undertaken to confirm physical properties of installed junction seal fittings. Each test listed below shall be undertaken at a minimum rate of 1 for every 20 installation.

- Hardness in accordance with ASTM D2583
- Short term tensile strength in accordance with ASTM D638 or BS 2782:Method 1003 (3 samples for each line being tested)
- Short term flexural strength and flexural modulus in accordance with ASTM D790 or BS 2782 Method 335A (3 samples for each line being tested) OR short term ring stiffness in accordance with AS 3572.10.

Samples for testing may be prepared using the procedure given in Appendix B of WIS 4-34-04.

The Contractor shall carry out hydrostatic test of the junction seal fitting under installed condition using lateral packer to confirm the watertightness of the installation. The hydrostatic testing shall be carried out in accordance with the requirements given elsewhere in the specification.

4.6 Reporting

Copies of quality log-sheets documenting each task and a CCTV recording for each of the junction sealed shall be submitted to the Principal. In case of any defect repaired, it shall be recorded on the CCTV recording and submitted with a written report describing fully the nature of defect and rectifications achieved.

5. References

Document type	Title	Document Reference (Section, clause)
Policies and procedures	Asset Creation Policy	
Other documents	SS201 Linings for Circular Non Man Entry Pipes SS209 Ling repairs of Non Man Entry Oviform Sewers	

6. Ownership

Ownership

Role	Title
Group	Asset Lifecycle
Owner	Engineering Manager, Engineering
Author	Robert Loncar, Specialist Engineering, Lead Civil Engineer

Change history

Version No.	Date	Approved by	Comments
4	23/02/2022	Norbert Schaeper, Engineering Manager	Transferred content to new Sydney Water Standard Template
3	25/06/2012	Peter Gillman – Manager, E2S	Revision and renaming of EPS 207 issued in March 2009
2	28/02/2012	Jerry Sunarho	Document reviewed and updated
1	08/11/2011	Janssen Chan	New Document