

NOTES:

1. REFER NOTES ON DRAWING NO. DTC/6042.

PIPE SCHEDULE - ALL CHAMBER PIPEWORK						
GAS CHECK MAINTENANCE HOLE STRUCTURE - DTC/6017						
ITEM	NO	DESCRIPTION	PIPE DIA	LENGTH	MATERIAL	REMARKS
71	2	SP X SP PIPE			GRP/PP	SN10000 ROCKER PIPE REFER TO TABLE 1 DTC/6016
72	4	PIPE COUPLING (EPDM SEAL)			GRP/PP	REQUIRED IF ERS PIPE IS GRP
73	1	SP X SP PIPE		1000	GRP/PP	SN10000
74	1	SP X SP PIPE		600	GRP/PP	SN10000
75	1	GAS FLAP VALVE			GRP	MULTITUBE MULTI N TYPE COUPLING CONNECTION NON RETURN VALVE OR APPROVED EQUIVALENT
76						
77						
BY-PASS - DTC/6041						
ITEM	NO	DESCRIPTION	PIPE DIA	LENGTH	MATERIAL	REMARKS
80	1	GATE VALVE			DI	RESILENT SEATED. MATCH DISCHARGE PIPEWORK SIZE UP TO DN200 c/w HAND WHEEL
81	1	NON RETURN VALVE			DI	FULL BORE, LONG BODIED SWING CHECK TYPE MATCH DISCHARGE PIPEWORK SIZE UP TO DN200. PROVIDE DN15 PLUG ON TOP OF VALVE BONNET
82	1	COUPLING				REFER TO NOTE 1 ON DTC/6028 MATCH DISCHARGE PIPEWORK SIZE UP TO DN200
83	1	FL X FL PIPE		250	DI	MATCH DISCHARGE PIPEWORK SIZE UP TO DN200
84	2	FL X FL 90 BEND			DI	MATCH DISCHARGE PIPEWORK SIZE UP TO DN200
85	1	FL X FL PIPE		1000	DI	MATCH DISCHARGE PIPEWORK SIZE UP TO DN200 WITH PUDDLE FLANGE 592mm OFF FL
86	1	FL X SO CONNECTOR			DI	MATCH DISCHARGE PIPEWORK SIZE UP TO DN200
87						
88						

DENOTES CELL TO BE COMPLETED AS PART OF SITE SPECIFIC DESIGN

DENOTES CELL NOT REQUIRED



© COPYRIGHT
STATE OF NEW SOUTH WALES THROUGH SYDNEY
WATER CORPORATION. ALL RIGHTS RESERVED

APPROVED

NORBERT SCHAEPER

MANAGER – ENGINEERING

ENGINEERING & TECHNICAL SUPPORT

A	ORIGINAL ISSUE (PREVIOUSLY DRAWING DTC/6030)	NS	25/06/21
LETTER	DETAILS OF ISSUE / AMENDMENT	APP'D	DATE

DEEMED TO COMPLY DRAWINGS

SEWAGE PUMPING STATION
PIPEWORK
SCHEDULE SHEET 2 OF 2

DTC

6043

ISSUE	DATE
A	25/06/21