

REFERENCE DRAWINGS

DTC-7018P&ID LINE LEGEND & INSTRUMENTATION SYMBOLS.
DTC-7019P&ID PREFIXES AND PIPING CODES.
DTC-7020P&ID LEGEND SYMBOLS SHEET.

NOTES:

1. FOR GENERAL NOTES REFER TO DRG No. DTC-7002.
2. FOR MULTIPLE DOSING POINTS REFER TO 27kL P&ID FOR CHANGE IN CONTROL VALVE LOCATION AND CARRIER WATER LINE SIZE.
3. PTX REQUIRED FOR MAINS DOSING ONLY.
4. SPOOL PIECE TO BE SUPPLIED FOR REMOVAL OF FLOWMETER.

THIS DRAWING MAY ONLY BE USED IN THE COURSE OF AND FOR THE PURPOSE OF CREATING SYDNEY WATER ASSETS. USE THIS DRAWING WITH CARE. YOU ARE RESPONSIBLE TO APPLY THE WORK SHOWN IN THIS DRAWING CORRECTLY IN THE CIRCUMSTANCES OF YOUR PROJECT. YOU MUST ENSURE THE WORK IS FIT FOR PURPOSE AND WILL PERFORM ITS INTENDED FUNCTION AS REQUIRED.

