



NOTES:


- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE DEEMED TO COMPLY DRAWINGS AS LISTED ON DRAWING DTC/6301.
- COIL EXCESS CABLE AT TOP OF TANK ACCESS POINT.
- USE CHEMICAL ANCHOR HILTI HIT 150 OR APPROVED EQUIVALENT.
- HEAVY DUTY uPVC CONDUIT TO AS2053 AND MINIMUM DIAMETER 50mm.
- EACH ANCHORAGE POINT SHALL BE TESTED USING A HYDRAULIC CYLINDER ATTACHED TO A TEST CELL CAPABLE OF MEASURING A STATIC TENSILE FORCE OF 15 kN. THE ANCHORAGE POINT SHALL BE PROOF LOADED AXIALLY TO 50% OF THE ULTIMATE STRENGTH REQUIREMENT AS SPECIFIED IN AS/NZS1891.
- THREE FLOAT SWITCHES ARE REQUIRED PER TANK. FOR DETAILS RELATING TO THE PURPOSE AND OPERATION OF FLOAT SWITCHES REFER TO THE INTERIM OPERATING PROCEDURE FOR EACH SITE.
- PV MOUNTING STRUCTURE SHALL COMPLY WITH AS 1170.
- REFER TO DTC/6313 FOR ELECTRICAL EQUIPMENT DETAILS.




SECTION 1
SCALE 1:5
DTC/6312




VIEW 4
SCALE 1:5




COMPONENT No. A200
SAFETY HARNESS ANCHOR DETAIL
SCALE 1:2




COMPONENT No. A400
FLOAT LEVEL SWITCHES WITH CABLE, TIES AND THIMBLES ASSEMBLY
SCALE 1:10
(REFER TO NOTE 6)




SECTION 2
SCALE 1:10
DTC/6316
COMPONENT No. A101
LOW LEVEL INDUCT VENT WITH PERFORATED PLATE COVER ASSEMBLY




COMPONENT No. S600
TEMPORARY FLOW DIVERSION MAINTENANCE HOLE
SCALE 1:25




COMPONENT No. 401
TANK OPERATING BEACON AND MOUNTING DETAIL
SCALE 1:2



DETAIL A
SCALE 1:2
HOOK DETAIL



COMPONENT No. S200
ELECTRICAL CUBICAL & SOLAR PANEL ARRANGEMENT
SCALE 1:25



Sydney
WATER

© COPYRIGHT
STATE OF NEW SOUTH WALES THROUGH SYDNEY
WATER CORPORATION. ALL RIGHTS RESERVED

APPROVED

KEN WIGGINS
MANAGER E & ES

ENGINEERING & ENVIRONMENTAL SERVICES

A
LETTER

ORIGINAL ISSUE

DETAILS OF ISSUE / AMENDMENT

KW

22/06/15

APP'D

DATE

DEEMED TO COMPLY DRAWINGS
TEMPORARY SEWAGE PUMP- OUT INSTALLATIONS
ASSEMBLY DETAILS
SHEET 1 OF 3

DTC
6310

ISSUE
A

DATE
22/06/15