North Head Water Resource Recovery Facility July Pollution Monitoring Summary Air Quality



EPL 378

Summary period: 01-07-2024 to 31-07-2024

Date obtained: 14-08-2024

Date published: 27-08-2024

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 33	Point descrip	Point description: Ventilation outlet at Scotts Creek							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	maximum limit	within limits*		
hydrogen sulphide gas	mg/m ³	30 minutes	1488	<0.004	<0.004	5	yes		

EPA Point 34	Point description: Ventilation outlet at Lane Cove River West							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	maximum limit	within limits*	
hydrogen sulphide gas	mg/m³	30 minutes	1488	<0.004	<0.004	5	yes	

EPA Point 35	Point description: Ventilation outlet at North Head STP for Northside Storage Tunnel							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	maximum limit	within limits*	
hydrogen sulphide gas	mg/m³	30 minutes	1488	<0.01	0.10	5	yes	

EPA Point 63	Point description: Central scrubber outlet at North Head STP							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	maximum limit	within limits*	
chlorine gas	mg/m ³	30 minutes	1488	<0.15	1.17	200	yes	
hydrogen sulphide gas	mg/m ³	30 minutes	1488	<0.075	1.41	5	yes	

EPA Point 66	Point description: Bio Trickling Filter / Standby Scrubber at North Head STP						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	maximum limit	within limits*
chlorine gas	mg/m ³	30 minutes	1488	<0.59	<0.59	200	yes
hydrogen sulphide gas	mg/m ³	30 minutes	1488	<0.071	0.21	5	yes

^{*}Maximum limits for air quality are based on the Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant.