

Bondi Wastewater Treatment Plant

2023-24 Air quality pollution monitoring summaries

EPL 1688

Summary period: 1-07-2023 to 30-06-2024

Date published: 01-09-2024

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 12	Point description: Air sampling outlet of cogeneration facility					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	2	428	430	431

Yearly measurement was taken on 12-01-2024.