

Wollongong Wastewater Treatment Plant

2023-24 Air quality pollution monitoring summaries

EPL 218

Summary period: 1-07-2023 to 30-06-2024

Date published: 01-09-2024

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 29	Point description: Air sampling outlet of cogeneration facility					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	424	441	450

Yearly measurement was taken on 02-02-2024.